Government of Andhra Pradesh

A.P. State Disaster Response and Fire Services Department

Annual Periodical Renewal Fire Certificate

From: District Fire Officer Andhra Pradesh, West Godavari

To:

Secretary,, AP State Council of Higher Education, Mahendra Enclave, 1st Floor, Tadepalli, Guntur-522501, Guntur District, AP

File No: 13966/WG/DFO/2020, Date:02/09/2020 Occupancy NoC RC Number: 4478/WG/DFO/2018

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Annual Periodical Fire Certificate to the constructed Non Multi Storeyed Building of Vishnu Institute of Technology(Revised Occupancy), represented by D Suryanarayana, Vishnupur, Bhimavaram - Regarding.

- Ref:
- 1. G.O.Ms.NO.71 Home (Prisons-A) Department, Dated.01-04-2010 & G.O.Ms.NO.140 Home(Prison & Fire Services) Department, Dt.04-09-2015.
- 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.09-03-2017.
- 3. This Office NOC for Occupancy Rc No. 4478/WG/DFO/2018, Dt.01/10/2018
- 4. Renewal NOC For Occupancy 4478/WG/DFO/2018, Dt.01/10/2019
- 5. Online Application for Renewal NOC of D Suryanarayana, Vishnupur, Bhimavaram Inspection report called for Regarding.
- 6. Online Inspection Report submitted by Officers of this Department on 31-08-2020.

<< 0>>>

The Management of Vishnu Institute of Technology(Revised Occupancy), represented by D Suryanarayana, Vishnupur, Bhimavaram has requested to issue Annual Periodical Fire Certificate for period 2017-2018 duly remitting the Fire Precautionary fee for Rs.411585/- vide challan No. 41121129392020, Dated 28/08/2020 at State bank of india, online.

Block 1 ,Block 4 ,Block 5 ,Block 3

,Block 2

1. This certificate is being issued as per G.O.Ms.No 140 Home (prisons & Fire Services) Department, Dt: 04.09.2015.

2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Annual Periodical Renewal Fire Certificate for vide reference 4th cited to the constructed Non Multi Storeyed Building.

3. The Officers of the department have recommended to issue The Annual Periodical Renewal Fire Certificate **D Suryanarayana Vishnupur, Bhimavaram**, subject to the following conditions.

SI	As Builder	As Occupant	As Security Personnel	
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.	
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.	
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.	

4. This Annual Periodical Renewal Fire Certificate is valid from 01/10/2020 to 30/09/2025.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

The following deficiencies are identified by the officers of the department and needs to be attended to by the management.

1. The Renewal NOC is issued from Fire Safety Point of view only basing on recommendation of the inspection committee and this renewal NOC is not for claiming proprietary or ownership rights. Further, in case of any deviation noticed with respect to this Renewal NOC after issuance of this Renewal NOC, the same Renewal NOC shall be liable for cancellation at any time. 2. This Renewal NOC is valid for Five years only and It is the responsibility of the Builder/Owner to apply for renewal of No Objection certificate, duly remitting the user charges as per G.O.Ms.No.169, Home (Prisons & Fire Service) Department. Dt. 19-12-2019. Two months before expire of this No Objection Certificate. 3. The occupier/Owner /Builder/Management concerned of the building premises, shall maintain the Fire Prevention and Fire Safety Measures provided by the building as per Occupancy NOC at all times for good use by the Occupant (or) Members of Fire Services (or) Both in the event of outbreak of Fire. 4. The Renewal NOC issued based on Inspection Committee report.



Your Sincerely

District Fire Officer Andhra Pradesh, West Godavari

GOVERNMENT OF ANDHRA PRADESH STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT

From :

The Director General, State Disaster Response and Fire Services, Andhra Pradesh, Vijayawada. To:

The Management, M/s. Vishnu Institute of Technology, located at R.S.No.75, Vishnupur, Kovvada Villagr, Bhimavaram, West Godavari District. 534202

Rc.No.6705/MSB/ER/WG/2022, Dt: /0.08.2022 9949400966

Sir,

- Sub: A.P. State Disaster Response and Fire Services Department-MSB Section-Issuance of No Objection Certificate for Occupancy to Educational Building of M/s. Vishnu Institute of Technology, located at R.S.No.75, Vishnupur, Kovvada Villagr, Bhimavaram, West Godavari District -Regarding.
- Ref: 1. This Office Provisional NOC issued vide Rc.No.2638/MSB/ER/WG/2021, Dt.16-07-2021.
 - Application of Educational Building of M/s. Vishnu Institute of Technology, located at R.S.No.75, Vishnupur, Kovvada Villagr, Bhimavaram, West Godavari District.
 - 3. Self Certification/Affidavit of the Management.

* * * * * * *

The Management has requested for issuance of No Objection Certificate for Occupancy to the existing Building of M/s. Vishnu Institute of Technology, located at R.S.No.75, Vishnupur, Kovvada Villagr, Bhimavaram, West Godavari District vide reference 2nd cited.

2) The Management has obtained Provisional NOC vide reference 1st cited and now, submitted the self certification for Educational building with Ground + (02) Upper floors with a height of 09.00 Mtrs, total built up area of 7928.19 Sq.Mtrs, and stated that they have provided the following Fire Safety Measures

3) It is suggested to the Management for providing the following Fire Safety Measures keeping in view of Practicality, Maintenance and Resilience:

Sl. Name of the No. Equipment		:	Fire Safety Measures		Deficit	
1.	Staircases	Stairca Lift wi Buildir	imum (02) shall be Provided .If the Second ase is not possible, provide Slider or Tube ith Exhaust Fan (connected outside to ng) or German Chute or horizontal ction between the neighborhood Buildings.		Nil	
2.	Fire Fighting Equipment.	2) Exti	inguishers (01 Extinguisher of ABC/CO2 r each Room).	09 No.'s	Nil	
		system		03 No's	Nil	
		Temper that ca instead	derground Parking / Cellar / Basement rature Sensor connected to "Hooter" and an be give alerts through Cell phone l of Sprinklers.	NA	Nil	
100			er Tank 5,000 Ltrs.,	15,000 Ltrs	Nil	
	1 10 1 10 10 1 1 1	6) 2 H connec Floor.	HP Motor with triplex Pump Shall be ted to normal plumbing system at each	03 Nos-2HP 01 No-5HP	Nil	

1

(contd....2p)

:: 2 ::

Sl. No.	Name of the Equipment	:	Fire Safety Measures	Available with Nos.	Deficit
			 7) Display the following Nos. at important areas (i) Fire Department number. (ii) Ambulance (iii) Police 	Displayed	Nil
		:	8) Maintained Fire Safety in the Auditorium Block/ Building.	NA	Nil
		:	9) Installation of Fire Safety Equipment in Library & Laboratory.	NA	Nil

The Management has provided the following Electrical Safety system:

-			
(i)	All Electrical wirings in the Building shall confirm the code of practise for Electrical wiring IS:732:1989 and also shall confirm for Fire Safety Wiring of the Building Electrical Installations as per IS:1646:2015. Most common mistake is that the neutral wires to the three pin plugs are not of sufficient thickness to carry the current in case of any short circuits.	;	Provided
(ii)	Installation of Miniature Circuit Breakers, (MCB's) in all Floors.		Provided
(iii)	No Overloading of power socket in any Educational Building.	:	Yes
(iv)	10 years old wiring to be changed specially where ever high power consuming appliances such as Air Conditioners, Electrical/Mechanical/ Computer labs, Data Centers, High tech labs, MRI machines, X-ray in Medical Colleges etc.,		Yes
(v)	Grounding / Earthing shall be done. For details refer IS 3043:1987.		Provided
(vi)			NA
	No High Tension Lines should run inside or in close proximity (< 6 meters) to any Educational institution Buildings.	res	
(viii)	All the above Safety Measures shall be certified by the authorized Electrical Engineer.	:	Certified

5) The Management has stated that, they satisfied with the installations and maintenance of the Fire Safety Equipment working condition in the Building and also they declared that no additions or alterations have been made in the Building affecting Fire Prevention and Fire Safety Measures including Means of Escape and that all Exits and Passages are free from any obstruction.

6) In view of the above, based on the self certification submitted by the Management and also taking into consideration of the larger public interest and in the context of the COVID-19 pandemic across the country, the No Objection Certificate for Occupancy is issued to the Existing Building of M/s.Vishnu Institute of Technology, located at R.S.No.75, Vishnupur, Kovvada Villagr, Bhimavaram, West Godavari District with Ground + (02) Upper floors with a height of 09.00 Mtrs, total built up area of 7928.19 Sq.Mtrs, and stated that, they have provided the Fire Safety Measures for Educational Occupancy.

The Management shall ensure the following conditions:
 (i) The Management is responsible for all risks invol

The Management is responsible for all risks involved in case of Fire Accident.

- (ii) This NOC is given based on the information, documents and drawings provided by the applicant. The applicant confirms that the information provided and the documents and drawings submitted are correct. Any deviation noticed will lead to cancellation of NOC without any notice.
- (iii) The permission accorded does not confer any ownership rights. If it is found that the information furnished is false and fabricated, the permission will be revoked at any stage and the applicant will be liable for criminal prosecution as per IPC.

(A)

(contd....3p)

8) It is informed that, the Management is requested to maintain the following conditions compulsorily for Safety purpose.

Sl.No.	As Builder	As occupant	As Security Personnel
1	All the Fire protection arrangements shall be maintained in good condition at all times.	All the Escape/Exit routes shall not be kept	All the Occupants must know the correct method of operation
2	Any loss of life or property due to non-functioning of Fire Safety Measures and other installations shall be the responsibility of the Management.	Safety Equipment during	conducted once in 03 months for initial two years. Thereafter,
3	Addition/alteration, if any in the Building may be verified by Building authority.	Mock drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.	trained to operate the Fire Safety Equipment during
4	This No Objection Certificate for Occupancy issued only from Fire Safety point of view.	Raise the alarm if the Fire cannot be controlled; Evacuate the area completely at once with nearest Safe Exit.	Fire Equipment only if you feel capable of controlling. If not,

9) This No Objection Certificate is issued, subject to the outcome of O.As/W.Ps etc., if any, before Courts etc.,

10) This No Objection Certificate for Occupancy is valid for a period of Five years from the date of issue of this letter to the management M/s.Vishnu Institute of Technology, located at R.S.No.75, Vishnupur, Kovvada Villagr, Bhimavaram, West Godavari District subject to the compliance of above Fire and Electrical Safety Measures. <u>The Owner/Occupier/Builder/Management concerned of the Building shall submit Self Declaration/Affidavit / Certification with regard to working condition of above Fire Safety System every year in the prescribed format and submit/upload the photographs of the Mock Drills conducted in the premises. It is the responsibility of the Builder to maintain the Fire Safety Equipment in good working condition at all times and apply for next Periodical Renewal of No Objection Certificate, duly remitting the User Charges vide G.O.Ms.No.90, Home (Prisons & Fire Services) Department Dated:13.08.2021 & G.O.Ms.No.120, Home (Prisons & Fire Services) Department Dated:25.10.2021, two (02) months before expiry of this of No Objection Certificate.</u>

Yours Sincerel Director General,

State Disaster Response and Fire Services, Andhra Pradesh, Vijayawada.

Copy to the Registrar, JNTUK, Kakinada.

Note: In case of any Emergency Call to 101 or State Fire Control Room-9100108101.